Health Department, Haryana (Faridabad)

O/o Civil Surgeon, Faridabad

Hygiene Certificate

No. ...HHC/Fbd\2025-26\110 Date ..25:7:2025.....

Certified that the inspection of the ..Royal..Convent..School..

..Gali No:-4..Near..MTNL..Tower,..Bhagat..Singh...Colony.....

faridabad School has been carried out on Date..23:7:2025.....The

Hygienic condition was found

satisfactory/Unsatisafactory

The above Certificate is valid till ..31:3:2026.... Date

Jayant

Signature with Seal

Dy. Civil Surgeon (School Health)

Faridabad

Scanned with OKEN Scanner

PUBLICHEALTHENGINEERINGDEPARTMENT

PHED Haryana

DISTRICTWATERTESTINGLABORATORY,FARIDABAD

Website :-https://phedharyana.gov.in/

Memo No:-**1096** Date:-**24/06/2025** Certificate No:**TC-9082**

Subject : Physical / Chemical Examination Report of Water Sample

		Sample Details	Date &Time
Sample ID/Classification :	FBD/01616/6/2025/ Private	Collected By	ROYAL CONVENT ...
Sender :	ROYAL CONVENT SCHOOL	Collection Date	18/06/2025 at 14:50
Location :	, BHAGAT SINGH COLONY GALI NUMBER 4 BALLABGARH FAR	Received at lab	19/06/2025 at 11:20
Sample Description :	Drinking Water	Analysis Start Date	19/06/2025
		Analysis End Date	20/06/2025
Latitute / Longitude :	77.327269 / 28.345279	Sample Quantity	1 Litre

Test Result(As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.93	1NTU	5NTU	APHA 24th edition,2130B:2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part8):2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part5):2018
4	Color	9	5 Hazen Units	15 Hazen Units	APHA 24th EDITION-2120 C:2023
5	Total Dissolved Solids @ 180°c ± 2°c	1396	500mg/lt.	2000mg/lt.	APHA 24th Edition-2540C
6	TotalHardnessasCaCo3	340	200mg/lt.	600mg/lt.	APHA 24th dition-2340C
7	Calcium as Ca	488.97	75 mg/lt.	200mg/lt.	APHA 24th Edition-3500-CaB
8	Magnesium as Mg	52.97	30 mg/lt.	100mg/lt.	APHA 24th Edition-3500MgB
9	Total Alkalinity	710	200mg/lt.	600mg/lt.	APHA 24th Edition-2320B
10	Chloride as Cl	191.25	250mg/lt.	1000mg/lt.	APHA 24th Edition-4500Cl-B
11	Sulphate as So4	89	200mg/lt.	400mg/lt.	USEPA /APHA 24th-4500SO4-E
12	Fluoride as F	0.78	1.0mg/lt.	1.5mg/lt.	APHA 24th Edition4500F-D:
13	Iron as Fe	0.03	1.0mg/lt.	1.0mg/lt.	USEPA 45(126:43459):2023,APHA 24th EDITION 3500-Fe-B
14	NitrateasNo3	5.92	45 mg/lt.	45 mg/lt.	APHA 24th Edition-4500NO3D
15	pH @ 25°c	7.76	6.5-8.5	6.5-8.5	APHA 24th Edition4500-H+B

Remarks :-

* The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
* The test report can't be used for any publicity or any legal purpose.
* Reliability of water sample sample lies with sender/collector of water sample.
* To check the sample report online Scan the QR Code below.
* Thetestsamplesmeantforchemicalanalysiswillbedisposedoffafter7daysfromthedataofissueoftest report unless untill specifically requested by the customer for retaining over a longer period.

Sample analyzed by :

VANDANA DESWAL,CHEMIST
DISTRICTWATERTESTINGLABORATORYF,ARIDABAD
email:-chemist.fbad@phedharyana.gov.in

PUBLIC HEALTH ENGINEERING DEPARTMENT, HARYANA	
Payment Receipt Of Water Sample Test (Consumer Copy)	
Test ID : S44995	**Date :** 18-Jun-2025 02:52:23 PM
Received from : ROYAL CONVENT SCHOOL	**Lab Name :** FARIDABAD Distt. Lab.
District : FARIDABAD	**Chemist:** VANDANA DESWAL
Town : Faridabad (MC)	**Sample Location :** BHAGAT SINGH COLONY GALI NUMBER 4 BALLABGARH FARIDABAD HARYANA
Ward : 1	**Address :**
By : Online Payment	
Online Transaction No. : Se9b2dc1f02fdbc4b2a1	**GRN No. :** 135560497
Test Name: Physical & Chemical Test	
Test Parameter	
Total Dissolved Solids @ 180°c ± 2°c	
Total Hardness as CaCo3	
Calcium as Ca	
Magnesium as Mg	
Iron as Fe	
Chloride as Cl	
Sulphate as So4	
Fluoride as F	
Nitrate as No3	
pH @ 25°c	
Total Alkalinity	
Color	
Odour	
Taste	
Turbidity	
Free Residual Chlorine	
Rs. 1000 (In words ONE THOUSAND only)	

ROYAL CONVENT EDUCATION SOCIETY

President

Principal
ROYAL CONVENT SCHOOL
Ballabgarh